



FLOORSTANDING MODULAR CABINET



FLOORSTANDING MODULAR CABINET





SEISMIC (EARTHQUAKE) RESISTANCE TEST REPORT

TEOS POWERED FRAME STRUCTURE

ZONE 3

<p><b>1. GENERAL DATA</b></p> <p><b>1.1. Customer</b> TEKPAN TEKNİK ELEKTRİK, Ankara Asfaltı 14 km. İstiklal Mh. 17 Sk. No:8 Uludağ Kurumları / İstasyon TURKEY</p> <p><b>1.2. Unit under test</b> The tests were performed on the following unit: • TEOS plus double door enclosure, with a total mass of 395 kg.</p> <p><b>1.3. Manufacturer</b> TEKPAN TEKNİK ELEKTRİK</p> <p><b>1.4. Reference documents</b></p> <p><b>1.4.1. Contract documents</b> a. Offer P&amp;P LMC No. OF-AR-04112 rev.01, dated June 18<sup>th</sup>, 2012. b. Order Tekpan dated June 19<sup>th</sup>, 2012.</p> <p><b>1.4.2. Technical documents and standards</b></p> <ol style="list-style-type: none"> <li>Teknik Genişletme Yönetmeliği (TR-43) CENELEC, NEBS Requirements: Physical Protection, Issue 1, October 1995.</li> <li>IEC 60068-3-3: Environmental testing - Part 3: Guidelines - Seismic test methods for equipment.</li> <li>IEC 60068-2-6: Environmental testing - Part 2: Tests - Test Fc: Vibration (random).</li> <li>IEC 60068-2-7: Environmental testing - Part 2: Tests - Test Fc: Vibration - Time history method.</li> <li>IEC 60068-2-8: Environmental testing - Part 2: Tests - Test Fc: Vibration - Time history method.</li> </ol> <p><b>1.5. Test objective</b> The purpose of the tests was to demonstrate that the unit behaves in compliance with the requirements stated in the IEC 60068-2-7 referring to a seismic risk classified as Zone 3.</p> <p><b>1.6. Tests overall results</b> At the end of the tests, as a result of inspection, no damages on the unit were detected.</p>	<p><b>1.7. Testing laboratory</b> P&amp;P LMC S.r.l. Via Panzavalle, 9 20098 Sesto San Giovanni (BG) ITALY</p> <p><b>1.8. Test date</b> October 17<sup>th</sup> - 18<sup>th</sup> - 19<sup>th</sup> - 20<sup>th</sup>, 2012.</p> <p><b>1.9. Responsibilities</b> A. Beati, test responsible M. Ceresa, test engineer D. Rossetti, test engineer</p> <p><b>2. TESTING PROCEDURES</b></p> <p><b>2.1. General remarks</b> To perform the tests, three reference directions have been considered for the unit: X (front - rear), Y (side - side) and Z (vertical). The sequence of the tests for the unit has been: • Seismic tests, performed in three directions (X, Y, Z) and consisted in: - vibration response investigation - earthquake - vibration response investigation All the applied vibration were manufactured. Tests in Z direction were performed on a vertical shaking table acted by an electro-dynamic shaker. For the other vibration directions, a horizontal shaking table was used. Excitation directions are shown in the photographs. All the performed tests are listed in the table of page from 15. Tests were assessed following the chronological sequence.</p> <p><b>2.2. Mounting techniques</b> For all tests the unit was mounted in its intended operating configuration. The unit was fixed to the shaking table with No. 12 M14 screws with a tightening torque of 80 Nm.</p> <p><b>2.3. Control and measuring positions</b> During the tests, for the motion control the signal of a non-resonant accelerometer in the excitation direction (FTI) was used. Moreover two modal accelerometers (MFI and MFD) were placed on the unit for the vibration measurement (see photos). In the table reported below are summarized model and serial number of the transducers mounted in the control and measuring positions during the tests.</p>
---	---

ZONE 4

<p><b>1. GENERAL DATA</b></p> <p><b>1.1. Customer</b> TEKPAN TEKNİK ELEKTRİK, Ankara Asfaltı 14 km. İstiklal Mh. 17 Sk. No:8 Uludağ Kurumları / İstasyon TURKEY</p> <p><b>1.2. Unit under test</b> The tests were performed on the following unit: • TEOS Plus single door enclosure, with a total mass of 313 kg.</p> <p><b>1.3. Manufacturer</b> TEKPAN TEKNİK ELEKTRİK</p> <p><b>1.4. Reference documents</b></p> <p><b>1.4.1. Contract documents</b> a. Offer P&amp;P LMC No. OF-AR-04112 rev.01, dated June 18<sup>th</sup>, 2012. b. Order Tekpan dated June 19<sup>th</sup>, 2012.</p> <p><b>1.4.2. Technical documents and standards</b></p> <ol style="list-style-type: none"> <li>Teknik Genişletme Yönetmeliği (TR-43) CENELEC, NEBS Requirements: Physical Protection, Issue 1, October 1995.</li> <li>IEC 60068-3-3: Environmental testing - Part 3: Guidelines - Seismic test methods for equipment.</li> <li>IEC 60068-2-6: Environmental testing - Part 2: Tests - Test Fc: Vibration (random).</li> <li>IEC 60068-2-7: Environmental testing - Part 2: Tests - Test Fc: Vibration - Time history method.</li> <li>IEC 60068-2-8: Environmental testing - Part 2: Tests - Test Fc: Vibration - Time history method.</li> </ol> <p><b>1.5. Test objective</b> The purpose of the tests was to demonstrate that the unit behaves in compliance with the requirements stated in the IEC 60068-2-7 referring to a seismic risk classified as Zone 4.</p> <p><b>1.6. Tests overall results</b> At the end of the tests, as a result of inspection, no damages on the unit were detected.</p>	<p><b>1.7. Testing laboratory</b> P&amp;P LMC S.r.l. Via Panzavalle, 9 20098 Sesto San Giovanni (BG) ITALY</p> <p><b>1.8. Test date</b> October 17<sup>th</sup> - 18<sup>th</sup>, 2012.</p> <p><b>1.9. Responsibilities</b> A. Beati, test responsible M. Ceresa, test engineer D. Rossetti, test engineer</p> <p><b>2. TESTING PROCEDURES</b></p> <p><b>2.1. General remarks</b> To perform the tests, three reference directions have been considered for the unit: X (front - rear), Y (side - side) and Z (vertical). The sequence of the tests for the unit has been: • Seismic tests, performed in three directions (X, Y, Z) and consisted in: - vibration response investigation - earthquake - vibration response investigation All the applied vibration were manufactured. Tests in Z direction were performed on a vertical shaking table acted by an electro-dynamic shaker. For the other vibration directions, a horizontal shaking table was used. Excitation directions are shown in the photographs. All the performed tests are listed in the table of page 15. Tests were assessed following the chronological sequence.</p> <p><b>2.2. Mounting techniques</b> For all tests the unit was mounted in its intended operating configuration. The unit was fixed to the shaking table with No. 8 M14 screws with a tightening torque of 80 Nm.</p> <p><b>2.3. Control and measuring positions</b> During the tests, for the motion control the signal of a non-resonant accelerometer in the excitation direction (FTI) was used. Moreover two modal accelerometers (MFI and MFD) were placed on the unit for the vibration measurement (see photos). In the table reported below are summarized model and serial number of the transducers mounted in the control and measuring positions during the tests.</p>
---	---

- Zone3' All Teos series products are within the scope of Zone 3 seismic resistance tests.
- Zone3' test was conducted for double-door enclosures of size 1200 widthx2000+100 height and 600 mm depth, and covers all sizes and types of the Teos series.
- You can view the complete report on our websites.

- For 'Zone 4' seismic resistance tests, an enclosure sized 800 width x 2000+100 height x 800 with an extra reinforced interior and welded plinth was used.
- The abovementioned size and structure are required for your needs within the scope of 'Zone 4'. Please contact our sales department for your needs.
- You can view the complete report on our websites



Turkish Patent No: TR 201009615Y

Produced with a closed rail structure, Teos enclosure rails are clamped with a special non-welded clamping system. Their resistance to both vertical and horizontal pressures is extremely high compared to open rail structures. This force enables full resistance for the movement of the installed equipments and resistance in overcurrents.

UL CERTIFICATE VALID CERTIFICATE IN THE USA AND CANADA

**CERTIFICATE OF COMPLIANCE**

Certificate Number: 20120920-E352599  
Report Reference: E352599-20120920  
Issue Date: 2012-SEPTEMBER-20

Issued to: TEKPAN - TEKNİK ELEKTRİK KUMANDA PANO SAN VE TURİZM TİCARET LTD ŞTİ ANKARA ASFALTI 14 KM İSTİKLAL MH 17 SK NO 8 TURKEY

This is to certify that representative samples of INDUSTRIAL CONTROL PANELS Enclosures for Industrial Control Panels, Sheet metal enclosure Series TEOS and DM.

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: Industrial Control Panels, UL 508A. Industrial Control Equipment, C22.2 No. 14-10

Additional Information: See the UL Online Certifications Directory at [www.ul.com/database](http://www.ul.com/database) for additional information

Only those products bearing the UL Listing Mark for the US and Canada should be considered as being covered by UL's Listing and Follow-Up Service meeting the appropriate requirements for US and Canada. The UL Listing Mark for the US and Canada generally includes: the UL in a circle symbol with "C" and "US" identifiers; the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product.

William R. Conroy, Director, North American Certification Programs, UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at [www.ul.com/customer](http://www.ul.com/customer)

Page 1 of 1

EAC CERTIFICATE

**ТАМЖОНЕННИЙ СОДЗ**  
**СЕРТИФИКАТ СООТВЕТСТВИЯ**  
№ TC\_RU C-TR.M010.B.01386  
Срок действия: № 0480583

ОРГАНИЗМ СЕРТИФИКАЦИИ Общество с ограниченной ответственностью «ЦЕНТР-СТАНДАРТ». Место нахождения: 191119, Российская Федерация, город Москва, Боровицкий проспект, дом 42, корпус 1С-3, этаж 1, комната 11. Адрес места осуществления деятельности: 117405, Российская Федерация, город Москва, улица Бородинская, дом 1, корпус 1, 3-й этаж, комната № 11. Телефон: +7 (495) 664-2398. Адрес электронной почты: info@center-cert.ru. Адрес аккредитации: регистрационный № RA.RU.115019. Дата регистрации аккредитации: 20.08.2015 года.

ЗАЯВИТЕЛЬ Общество с ограниченной ответственностью «СЭС Космонавт». Основное государственное регистрационное номер: 110704007714. Место нахождения: 185017, Российская Федерация, город Москва, улица 3-я Парковая, дом 9, квартира 18. Телефон: 7929524611, адрес электронной почты: s@cosmonaut2000@gmail.com

ИЗГОТОВИТЕЛЬ «ТЕКΠΑΝ TEKNİK ELEKTRİK KUMANDA PANO SAN VE TİCARET LİC.A.Ş.» Место нахождения: ТУРКІЯ, Кемерде О.С.Б. Исткял Мх. 17 Ск.Но.8 Улудаг Курумлари/Иstasyон

ПРОДУКЦИЯ Электро релейные терминалы «ТЕКΠΑΝ», артикулы: 990.200, 990.201, 990.202, 990.203, 990.204, 990.205, 990.206, 990.207, 990.208, 990.209, 990.210, 990.211, 990.212, 990.213, 990.214, 990.215, 990.216, 990.217, 990.218, 990.219, 990.220, 990.221, 990.222, 990.223. Предприятие изготовлено в соответствии с Декретом 2014/35/ЕС «Наказательное постановление». Серийный выпуск.

КОД ТН ВЭД ТС: 8536 69 900 8

СООТВЕТСТВУЕТ ТРЕБОВАНИИМ Технического регламента Таможенного союза ТР ТС 004/2011 «О безопасности низковольтного оборудования»

СЕРТИФИКАТ ВЫДАН НА ОСНОВАНИИ протокола испытаний № 1084/01/ЭИ.М.2017 от 03.10.2017 года, выданного Исполнительным директором Общества с ограниченной ответственностью «ПРОМАИТЕСТ», аттестат выданной регистрационный № RA.RU.115019, членом комиссии по сертификации Таможенного регламента Таможенного союза ТР ТС 004/2011 «О безопасности низковольтного оборудования» ГИСТ 2011.1.2012. Ссылочные стандарты: ГОСТ Р 51330.1-2013 «Системы электротехнических аппаратов. Часть 1. Общие требования и методы испытаний». ГОСТ Р 51330.2-2013 «Системы электротехнических аппаратов. Часть 2. Дополнительные требования и методы испытаний для выключателей и предохранителей». ГОСТ Р 51330.3-2013 «Системы электротехнических аппаратов. Часть 3. Дополнительные требования и методы испытаний для выключателей и предохранителей».

Срок сертификации: 1с

ДОПОЛНИТЕЛЬНАЯ ИНФОРМАЦИЯ Срок службы технических устройств: Срок и условия хранения указаны в сопроводительной документации, прилагаемой к изделию. Стандарт, обязательное применение которого Таможенным регламентом Таможенного союза ТР ТС 004/2011 «О безопасности низковольтного оборудования» ГИСТ 2011.1.2012. Ссылочные стандарты: ГОСТ Р 51330.1-2013 «Системы электротехнических аппаратов. Часть 1. Общие требования и методы испытаний». ГОСТ Р 51330.2-2013 «Системы электротехнических аппаратов. Часть 2. Дополнительные требования и методы испытаний для выключателей и предохранителей». ГОСТ Р 51330.3-2013 «Системы электротехнических аппаратов. Часть 3. Дополнительные требования и методы испытаний для выключателей и предохранителей».

Срок действия сертификата: 04.10.2017 ПО 03.10.2022

ВКЛАДЧИКОВ: Е.Н. Ушаков, В.А. Туканов

- You can view the complete report on our websites

TEOS EARTING CONTINUITIY




Placed on the aluminium corner combination, the earthing hooks are tightly mounted on the uncoated inner surface of the rails by means of eroding. Thereby, the earthing continuity is ensured for all rails and their parts

Placed on the bottom-top inner parts of the front door, the earthing screw increases conductive surface. Thereby, the front door is more efficiently grounded as the most important part to be grounded.

Applied to all other cover plates, the earthing screws allow for the complete earthing of all enclosure cover plates. Furthermore, TEOS allows for earthing all parts by use of special grounding washers.

TEOS CORROSION PROTECTION




Teos closed frame made by galvanized steel (DIN EN 10142\_00 DX51 D+Z) and coated Nano-plating and powder coated from outside of the surface. Non-powder coated inside surface can not corrode because of the galvanized material style.

Manufactured from aluminim-cast (E-160) material, the rail connection corners do not corrode thanks to their aluminim structure.

70-90 µm epoxy polyester powder-coating  
8-10 µm fosfat  
Metal

All coated parts respectively undergo the automatic processes of washing, Nano-plating, deionized passivation- drying- coating- firing and are treated with active coating. 500 hour salt test resistance is acquired according to the test results of this process

## TEOS EASY ASSEMBLING AND LOGISTICAL ADVANTAGES



1



2



3



4



Offered as flat package, the TEOS series is designed for an easy mounting in a minimal amount of time. It does not require angulation for the body and can be mounted between 15-20 minutes by two people.

Offered as flat package, TEOS series save space during transportation and storage. However, since packages can be replaced with each other, they provide more solutions with less inventory.

You can access the Teos assembly video by scanning the QR code.



## TEOS PLINTH SYSTEM



Front surfaces of the corner parts are open in the plinth system which is designed with a height of 100 mm and 200 mm. This enables not only an easy mounting on the enclosure but also an easy ground fixing. Upon the completion of this process, the plastic panel closes without use of screws.

Plinth front panels are mounted with screws while the side panels are screwed from the inside.

A separate corner can be used for plinth applications with a height of 200 mm as well as plinths with a height of 100 mm can be superimposed to reach the 200 mm height.

## TEOS FRONT DOOR

### Lock and hinge placed in four points




### Wheel Application



The standard wheel application that comes with TEOS+ products prevents the door from sagging, balances the weight of the door, and prevents harsh closing due to wind or other factors, thus protecting panels and accents against any mechanical impact.

### Wide Space and Strong Door Rail




Since locking is performed on the rails, inner space of the cover plates allows for a maximum efficiency.

As the closed support rails are manufactured as a completely closed box, they are more resistant to bending. This ensures a stronger cover plate.

### Comfort Handle Lock with Insert Protection




### Rigid and Durable Lock Structure



Lock failures experienced in most enclosures are prevented in TEOS. Thanks to their corrugated and long-lasting structure, the locking plates do not bend and corrode.

IP 54 - IP 65 PROTECTION CATEGORY


MOUNTING PLATE SYSTEM



Sealing foam gaskets are used on the body door, back door, side panels and top panels of the enclosure. This gasket enables complete isolation between -40 and +100 C

All gaskets apply pressure on the convex frame curves. Dust and water particles are left in the space between the convex curves, and thus pressure on the gasket is prevented.

All seal applications on the covers press on the convex curves in the carcasses. Dust and water droplets are left in the area between these convex curves and the pressure on the seal is prevented.



Applied to double-door enclosures, the insulating gasket assumes a full protective role between two panels and the frame when both doors close over the gasket.

Applied to all front doors and panels, the liquid seal is used in all double-door enclosures and acts as an insulator between two doors. Locking system of both doors work separately and this enables a full gasket pressing



Manufactured from a 3,00 mm galvanized steel, TEOS mounting plates are railed and easily mounted. With its thick steel sheet structure, the mounting plate can carry heavy equipment with its rigid structure and does not need additional side support parts. In this way, bayed enclosure space is increased in combined enclosures.



Connected to the mounting plates, the intermediate mounting plate increases space and can move back and front together with the mounting plates.

